



July 10, 2013

Mr. Marius Mueller

PROMET INC  
14135 East 42nd Avenue  
Suite 50  
Denver CO 80239  
Phone No: 1 303 371 2300  
E-mail: [marius.mueller@promet.com](mailto:marius.mueller@promet.com)

Subject: ProFlex Wiring System

Dear Mr. Mueller,

This is in response to your inquiry of July 1, 2013, concerning the Promet's "ProFlex wiring system" (See Fig. 1). The ProFlex systems are vertical and horizontal aluminum frames intended to provide mounting for components and associated wiring (as shown in Fig 2). Based on the above intended use, we believe there is no need for the aluminum extrusions used in the ProFlex wiring system to be UL Listed or Recognized.

FIG. 1


## ProFlex Wiring System

Horizontal profiles are mounted on the aluminum clamps





FIG. 2. (For reference only). Systems with component mounted must be investigated by UL before a UL Mark can be issued.



If there are additional questions or comments concerning this subject, please contact us.

Sincerely:

*Lenworth Grant*

Lenworth Grant  
Senior Staff Engineer  
Department: 3017AMEL  
Tel: 631 546 2553  
E-mail: [Lenworth.E.Grant@ul.com](mailto:Lenworth.E.Grant@ul.com)

Reviewed by:

*Salvatore Porcillo*

Salvatore Porcillo  
Engineering Manager  
3017AMEL  
631 546 2620  
[Salvatore.Porcillo@ul.com](mailto:Salvatore.Porcillo@ul.com)

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.